

Subject: Inquiry for CT-PT Set as per Tender Requirement – 500 kWp Captive Solar Power Plant (NHDC)

Dear Sir/Madam,

We are participating in the tender:

"Implementation of 500 KWp Captive Solar Power Plant near Hanuman Mandir at Omkareshwar Power Station (NHDC)" Tender No.: NHDC/3/C/298/NIT-720/24/1519.

As per the technical requirements of grid synchronisation, metering and protection, we require CT–PT equipment suitable for HT metering and solar integration. Kindly provide your detailed technical and commercial offer for the below-mentioned items along with required documents.

Required CT-PT Specifications

Sr. No.	Item Description	Technical Specification Required	Documents Needed
1	Current Transformer (CT)	 Ratio: 200/5A or 400/5A Class: 0.5s (Metering) Burden: 10 VA IS 2705 Compliant 	DatasheetGTPQAPType Test Reports
2	Potential Transformer (PT)	• Ratio: 11kV / 110V • Class: 0.5s • IS 3156 Compliant	DatasheetGTPQAPCalibration Certificate
3	Combined CT–PT Set	11kV Outdoor HT Metering Type Accuracy Class: 0.5s Oil-filled / Dry Type	OEM Certificate BIS/ISI Approval GA Drawings
4	HT Metering Panel	ABT Compatible CT–PT Interface IP54 Weatherproof Panel	GA Drawing QAP Wiring Diagram

Documents Required

- GTP (Guaranteed Jechnical Particulars)

C/o. Nobal Electrade Pvt. Ltd. "Noble Plaza", 2nd Floor,
2/15, Bhaktinagar Station Road, Rajkot - 360001. Gujarat, INDIA

BRANCH OFFICE

Shop No. 5, Ashapura Road, Opp. R.M.C. Gate No.2, Rajkot - 360001. Gujarat, INDIA



- QAP (Quality Assurance Plan)
- Datasheets
- Type Test Report (NABL Accredited Lab)
- Calibration Certificate
- BIS / ISI Approval Certificate
- OEM Authorization Letter
- Warranty Terms
- Delivery Schedule

Commercial Details Required

- Item-wise price
- GST % applicable
- Freight & transportation charges
- Delivery timeline
- Payment terms
- Quotation validity period

Kindly arrange to send your complete technical and commercial proposal at the earliest, as the same is required for tender submission and project execution.

Regards,